

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS

Hillside, New Jersey 07.

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com
REPORT # 360420009.0

CLIENT # DEN02N

DATE SUBMITTED: 4/20/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: Denville Township Water Dept. 140 Morris Avenue

Denville

NJ 07834

ATT: Thomas Andes

SAMPLE TYPE: POTABLE WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: VALLEYVIEW SCHOOL

DATE SAMPLED: 4/20/16 TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/21/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

295445



Garden State Laboratories, Inc.

Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS

07834

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360420010.0

CLIENT # DEN02N DATE SUBMITTED: 4/20/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

> TO: Denville Township Water Dept. 140 Morris Avenue

> > Denville NJ

ATT: Thomas Andes

SAMPLE TYPE: POTABLE WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: RIVERVIEW SCHOOL

DATE SAMPLED: 4/20/16 TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/21/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.